

Main Identity

From: <AlarmNotification@alarmagent.com>
To: <J.Beltman@racoman.com>
Sent: Thursday, May 19, 2005 12:31 PM
Subject: AlarmAgent detected an alarm on one of your RTUs!

Hello Jack Beltman,

This is the RACO AlarmAgent system, writing on behalf of Oak Bluff DPW to notify you of a change in status of one or more of your RTUs. To respond, please click on the link below or call 1-877-374-7932

RTU	Alarm Message	Alarm Date	Respond
Trinity Park Lift Station	High Wet Well Level Alarm	May 19, 2005 12:31:48 PM	Acknowledge/Snooze

AlarmAgent does not send unsolicited email. You are receiving this message because your email address was added to our call list for RTUs in this group. Please see your supervisor if this message should be directed elsewhere.